

# Certificate of Conformity

By the product certificate number:

No. 2623/0042-3-C-CER

Issued to:

License holder:

**AISWEI Technology (Shanghai) Co., Ltd.**  
Room 905B, 757 Mengzi Road, Huangpu District,  
200023 Shanghai, P.R. China

Trademark:



Manufacturer:

**AISWEI New Energy Technology (YangZhong) Co., Ltd.**  
No. 588 Gangxing Road, Yangzhong, Zhenjiang, China

It is certified that the product:

Type of generating unit: **Grid-connected PV Inverter**

Models:	ASW75K-LT	ASW80K-LT	ASW100K-LT	ASW110K-LT
Technical Data:				
Nominal power [W]	75000	80000	100000	110000
Nominal voltage [V]	3/N/PE; 230 V / 400 V			
Nominal frequency [Hz]	50 / 60			
Firmware version	Master Firmware version: V610-04001-02 Safety Firmware version: V610-12001-00			
Number of phases	Three Phases			
Isolation Transformer	No			

Is in compliance with the standard:

**IEC 62116:2014**

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.

This certificate is based upon the test results of the Test Report GZES220701316403

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 22<sup>nd</sup> February 2023

This certificate is valid until 22<sup>nd</sup> February 2028

Madrid, 22<sup>nd</sup> February 2023

Daniel Arranz Muñiz  
Certification Manager

